



WOOD NAILERS INSTALLED WITH BOND BREAKERS AND FASTENED AS SPECIFIED OR REQUIRED BY CODE OR INDUSTRY STANDARDS TO RESIST DESIGN LOADS AND CORROSION OF STEEL DECKING, FASTENERS AND METAL EDGING.

NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. SOPREMA ADHESIVES, CEMENTS, MASTICS, PRIMERS AND SEALANTS ARE REQUIRED WHERE INDICATED.
3. WHEN A PROJECT SPECIFICATION REQUIRES SOPREMA TO WARRANT SHOP FORMED METAL(S), ROOFING CONTRACTOR MUST SUBMIT METAL SPECIFICATION AND ALL PROPOSED METAL DETAILS TO THE SOPREMA CORPORATE TECHNICAL DEPARTMENT FOR REVIEW/APPROVAL PRIOR TO BIDDING AND/OR INSTALLATION.

- SPECIFIED METAL COUNTERFLASHING
- FASTENERS APPROX. 8" (203mm) O.C.
- NEW CAP MEMBRANE FLASHING PLY EXTEND 8" (203mm) OUT FROM CANT
- ON HEAT WELDED FLASHING EMBED NEW CAP GRANULES IN FLASHING AREA (TYP) 8" (203mm) OUT FROM CANT
- NEW FIELD CAP MEMBRANE PLY TIE-IN EXTEND 12" (305mm) OUT FROM CANT
- NEW FIRST MEMBRANE FLASHING PLY EXTEND 6" (152mm) OUT FROM CANT
- EXISTING FIELD CAP MEMBRANE PLY - ON HEAT WELDED FLASHING EMBED GRANULES IN FLASHING AREA (TYP) 12" (305mm) OUT FROM CANT
- EXISTING FIELD BASE MEMBRANE PLY
- COVERBOARD INSULATION (IF REQUIRED)
- THERMAL INSULATION (IF REQUIRED)
- ROOF DECK
- ALTERNATE CURB BEARING LOCATION FOR HEAVY WEIGHT LOADING CONDITIONS

PLOT DATE: 12/1/06
FILE NAME: WP631



310 QUADRAL DRIVE
WADSWORTH, OHIO 44281
(330) 334-0066

TITLE			
INSULATED NEW CURB/ROOF TIE-IN			
SCALE	DWN	CHK	APPROVAL DATE
NONE	DMT	BS	12/1/06
DRAWING NUMBER			REV
AC-009			0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.