

THERMAL INSULATION,
COVERBOARD AND ROOFING
PLIES APPLIED TO DECK AS
SPECIFIED OR REQUIRED

30" (762mm) SQUARE MINIMUM,
2 1/2 LB. TO 4 LB. (1.2kg TO 1.8kg)
LEAD OR 16 OZ. (0.5kg) COPPER
FLASHING SET IN SOPREMA MASTIC,
PRIME TOP SURFACE BEFORE STRIPPING.
(TYP.) SEE DETAIL DR-001 FOR
SPECIFIC CALL-OUTS.


REINFORCING
MEMBRANE PLY (TYP.)
EXTEND 3" (76mm)
BEYOND LEAD.

FIELD CAP MEMBRANE PLY

WHEN POSSIBLE INSTALL
MINIMUM 4" (102mm)
DRAIN SUMP IN ANY ONE
DIRECTION - OR THAT
ADDITIONAL TAPER TO
PROVIDE POSITIVE DRAINAGE.

NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. SOPREMA ADHESIVES, CEMENTS, MASTICS, PRIMERS AND SEALANTS ARE REQUIRED WHERE INDICATED.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066	
TITLE DRAIN SUMP W/ 4' TAPER			
SCALE NONE	DWN DMT	CHK PR	APPROVAL DATE 9/1/05
DRAWING NUMBER ADR-002			REV 0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.