


NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. SOPREMA ADHESIVES, CEMENTS, MASTICS, PRIMERS AND SEALANTS ARE REQUIRED WHERE INDICATED.
3. WHEN A PROJECT SPECIFICATION REQUIRES SOPREMA TO WARRANT SHOP FORMED METAL(S), ROOFING CONTRACTOR MUST SUBMIT METAL SPECIFICATION AND ALL PROPOSED METAL DETAILS TO THE SOPREMA CORPORATE TECHNICAL DEPARTMENT FOR REVIEW/APPROVAL PRIOR TO BIDDING AND/OR INSTALLATION.
4. ON SLOPES GREATER THAN 3/4:12, FIELD CAP MUST BE UNDER METAL EDGE AND STRIPPED-IN WITH EITHER THE ALSAN FLASHING SYSTEM OR HEAT WELDED STRIP-IN POLYESTER FIELD CAP MEMBRANE PLY.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281	
		(330) 334-0066	
TITLE			
METAL EDGE- GRAVEL STOP			
SCALE	DWN	CHK	APPROVAL DATE
NONE	DMT	PR	9/1/05
DRAWING NUMBER			REV
AE-001			0