



ALSAN FLASHING BASE COAT WITH ALSAN POLYFLEECE WHERE REQUIRED - SEE NOTE 3.

SUPPORTED/RESTRAINED WALL OR CURB SUBSTRATE SURFACE PREPARED AS REQUIRED BY SOPREMA TO RECEIVE ALSAN FLASHING MEMBRANE SYSTEM MINIMUM 2" HEIGHT.

WOOD NAILERS (IF REQUIRED) FASTENED AS SPECIFIED

1"
2"
2"
(5cm)

ALSAN PRIMER DEPENDING ON SUBSTRATE BEING COATED SEE NOTE 2.

UNIT MOUNTING CURB

REMOVABLE METAL COUNTERFLASHING EXTENDER PIECE

4" (10cm)

ALSAN FLASHING FINISH COAT-OPTIONAL TOP SURFACING OF EMBEDDED MATCHING GRANULES OR SOPREMA CURAL ALUMINIZER - WET 24 MILS (16 DRY MILS) SEE NOTE 5.

APPLY ALSAN FLASHING BASE COAT - SEE NOTE 4.

EITHER EXISTING SINGLE PLY OR MULTIPLE PLY SMOOTH OR GRANULATED ASPHALT BUR

COVERBOARD INSULATION (IF REQUIRED)

THERMAL INSULATION (IF REQUIRED)

ROOF DECK

NOTES:

1. USE DETAIL IN CONJUNCTION WITH ALSAN FLASHING SPECIFICATIONS, APPLICATION INSTRUCTIONS, COVERAGES AND APPROVED DETAILS.
2. "PROPERLY PREPARED SUBSTRATE" MEANS AN ACCEPTABLE, CLEAN, DRY SUBSTRATE WITH AN APPROVED SURFACE OR AN ALSAN PRIMER APPLIED OVER SINGLE PLY, MULTIPLE PLY SMOOTH OR GRANULATED ASPHALT BUR (WHERE REQUIRED), BASE COAT SURFACE (AFTER 7 DAYS) OR SURFACE WITHOUT GOOD ADHESION BOND TESTS.
3. SPLITS, BLISTERS, AND FISH MOUTHS, FLASHING AND SEAMS: APPLY ALSAN FLASHING BASE COAT AT 1.5 GALS (24 WET MILS OR APPROX. 18 DRY MILS) TO 3.0 GALS (48 WET MILS OR APPROX. 36 DRY MILS) PER 100 FT² OR THAT ADDITIONAL AMOUNT OF MATERIAL TO INSURE REPAIR AREA IS WATERTIGHT. AMOUNT OF COATING DEPENDS ON TYPE OF REPAIR. EMBED ALSAN POLYFLEECE REINFORCEMENT INTO DETAIL COAT WITHOUT WRINKLES OR FOLDS FOLLOWED BY ADDITIONAL COATING TO INSURE WATERTIGHT SEAL.
4. UNLESS OTHERWISE INDICATED, ALSAN FLASHING BASE COAT IS APPLIED IN ONE COAT AT A RATE OF 1.87 GALS/100 FT² OR APPROX. 30 WET MILS PER 100 FT² TO INSURE 22 DRY MIL THICKNESS AT THE APEX OF THE ROOF SURFACE AND TO INSURE WATERTIGHTNESS. UNLESS OTHERWISE INDICATED, ALSAN FLASHING FINISH COAT IS APPLIED IN ONE COAT AT A RATE OF 1.87 GAL (30 WET MILS OR APPROX. 22 DRY MILS) PER 100 FT² OR THAT ADDITIONAL AMOUNT OF MATERIAL TO INSURE A 22 DRY MIL THICKNESS AT THE APEX OF THE ROOF SURFACE AND TO INSURE WATERTIGHTNESS. CURAL 24 WET MILS COVERAGE RATE (DRY 16 MILS) IS 1.5 GAL/100 FT².
5. MILS OR APPROX. 22 DRY MILS) PER 100 FT² OR THAT ADDITIONAL AMOUNT OF MATERIAL TO INSURE A 22 DRY MIL THICKNESS AT THE APEX OF THE ROOF SURFACE AND TO INSURE WATERTIGHTNESS. CURAL 24 WET MILS COVERAGE RATE (DRY 16 MILS) IS 1.5 GAL/100 FT².



310 QUADRAL DRIVE
WADSWORTH, OHIO 44281
(330) 334-0066

TITLE				ALSAN FLASHING RECOVER ROOF ASSEMBLY	
SCALE	DWN	CHK	APPROVAL DATE		
NONE	DMT	PR	10/15/04		
DRAWING NUMBER					REV
AFC-003					0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.