

SEE APPROPRIATE METAL PARAPET CAP DETAIL

ADHERED SINGLE-PLY MEMBRANE WITH NO HEIGHT LIMITATION IF FLASHING MEMBRANE IS ONE PIECE FROM THE "Z" FLASHING TO THE OUTSIDE OF THE PARAPET WALL OR TWO PLY MODIFIED BITUMEN FASTENED EVERY TWO FEET WITH FASTENER AND 2" DIAMETER PLATE 8" O.C.

SOPREMA BONDING ADHESIVE FOR SINGLE PLY OR APPROPRIATE MODIFIED BITUMEN ADHESIVE MATERIAL.

8" MINIMUM
24" MAXIMUM
FLASHING HEIGHT

SHEET-METAL COUNTERFLASHING (PRIME PRIOR TO THE ADHESION OF ANY MEMBRANE) FASTENED WITH APPROPRIATE FASTENER 12" O.C. (MAXIMUM)

SOPREMA SBS MEMBRANE ROOF SYSTEM


COVERBOARD INSULATION (IF REQUIRED)

THERMAL INSULATION (IF REQUIRED)

ROOF DECK

NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. THIS DETAIL SHOULD BE USED ONLY WHERE THE DECK IS SUPPORTED BY THE WALL.
3. COUNTERFLASHING DETAIL MAY BE A TWO-PIECE REGLET AND COUNTERFLASHING.
4. THIS DETAIL MAY NOT BE USED WITH LWIC.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281	
		(330) 334-0066	
TITLE BASE FLASHING W/"Z" METAL @ HIGH WALL			
SCALE	DWN	CHK	APPROVAL DATE
NONE	DMT	BS	2/4/09
DRAWING NUMBER AHWBF-010			REV 0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.