


NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. SOPREMA ADHESIVES, CEMENTS, MASTICS, PRIMERS AND SEALANTS ARE REQUIRED WHERE INDICATED.
3. THIS IS A SOPREMA SUGGESTED DETAIL THAT THE SPECIFIER OF RECORD MAY CHOOSE TO USE. SOPREMA IS NOT A DESIGNER OF AIR TERMINAL AND CABLE BASE (AT & CB) COMPONENTS AND TO ADEQUATELY PROTECT A BUILDING FROM A DIRECT LIGHTNING HIT.
4. INSTALLER AND SPECIFIER ARE RESPONSIBLE TO INSURE COMPATIBILITY BETWEEN AT & CB METAL AND OTHER ROOF TOP METALS.
5. ON FOIL CLAD MEMBRANES—SCORE, HEAT AND REMOVE FOIL IN AREA WHERE AT AND CB WILL BE INSTALLED. APPLY 2-PART MEMBRANE ADHESIVE IN THIS AREA AND ADHERE AT & CB.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281 (330) 334-0066	
TITLE Air Terminal & Cable Base w/ 2-Part Adhesive			
SCALE	DWN	CHK	APPROVAL DATE
NONE	DMT	BS	12/1/06
DRAWING NUMBER			REV
APN-011			0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.