

EXTEND HIGH TEMPERATURE SELF-ADHERED MEMBRANE DOWN OUTSIDE FACE OF SOLID MASONRY WALL AND OVERLAP BASE FLASHING MIN. 2" (5mm)

APPROX. 1/2" (13mm) GAP

METAL JOINT COVER PLATE 6" (152mm) WIDE MIN. SET IN TWO BEADS OF SEALANT

CONTINUOUS TAPERED WOOD SHIM

METAL CAP

FASTENER AND SEALING WASHER SPACED AS SPECIFIED

MAXIMUM 24" (610mm)  
MINIMUM 8" (203mm)  
1" (25mm) MIN. BELOW BLOCKING

FASTENERS APPROX. 8" (203mm) O.C.

PRIMED MASONRY SUBSTRATE. ON HEAT WELDED FLASHING WITH WOOD SUBSTRATE, FASTEN SOPREMA APPROVED BASE SHEET 8" (203) O.C. IN GRID PATTERN AND AT SIDE LAPS. (NOT SHOWN)

ON HEAT WELDED FLASHING EMBED GRANULES IN FLASHING AREA

4" (102mm) MIN.

2" (51mm) MIN.

CAP PLY


THERMAL INSULATION, COVERBOARD AND ROOFING PLIES APPLIED TO DECK AS SPECIFIED OR REQUIRED

BASE PLY

WOOD NAILERS INSTALLED WITH BOND-BREAKERS AND FASTENED AS SPECIFIED OR REQUIRED BY CODE OR INDUSTRY STANDARDS TO RESIST DESIGN LOADS AND CORROSION OF STEEL DECKING, FASTENERS AND METAL EDGING.

NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. SOPREMA ADHESIVES, CEMENTS, MASTICS, PRIMERS AND SEALANTS ARE REQUIRED WHERE INDICATED.
3. WHEN A PROJECT SPECIFICATION REQUIRES SOPREMA TO WARRANT SHOP FORMED METAL(S), ROOFING CONTRACTOR MUST SUBMIT METAL SPECIFICATION AND ALL PROPOSED METAL DETAILS TO THE SOPREMA CORPORATE TECHNICAL DEPARTMENT FOR REVIEW/APPROVAL PRIOR TO BIDDING AND/OR INSTALLATION.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281	
		(330) 334-0066	
TITLE			
WALL BASE FLASHING			
SCALE	DWN	CHK	APPROVAL DATE
NONE	DMT	BS	12/1/06
DRAWING NUMBER			REV
AWBF-001			0

\*\* USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.