


- NOTES:
1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
  2. SOPREMA ADHESIVES, CEMENTS, MASTICS, PRIMERS AND SEALANTS ARE REQUIRED WHERE INDICATED.
  3. WHEN A PROJECT SPECIFICATION REQUIRES SOPREMA TO WARRANT SHOP FORMED METAL(S), ROOFING CONTRACTOR MUST SUBMIT METAL SPECIFICATION AND ALL PROPOSED METAL DETAILS TO THE SOPREMA CORPORATE TECHNICAL DEPARTMENT FOR REVIEW/APPROVAL PRIOR TO BIDDING AND/OR INSTALLATION.
  4. CAP FLASHING MUST BE INSTALLED UNDER THE METAL EDGE WHEN HOT MOPPED OR ADHERED WITH FLASHING ADHESIVE. METAL FLANGE STRIPPED IN WITH EITHER ALSAN FLASHING SYSTEM OR HEAT WELDED POLYESTER CAP MEMBRANE STRIP-IN PLY.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281	
		(330) 334-0066	
TITLE			
WALL BASE FLASHING W/ METAL EDGE			
SCALE	DWN	CHK	APPROVAL DATE
NONE	DMT	BS	12/1/06
DRAWING NUMBER			REV
AWBF-002			0

\*\* USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.