

SEAL TOP EDGE OF CAP MEMBRANE FLASHING PLY TO THE DECK WITH SOPREMA MASTIC

WOOD DECK

ON HEAT WELDED FLASHING, FASTEN SOPREMA APPROVED BASE SHEET 8" (203mm) O.C. IN GRID PATTERN AND AT SIDE LAPS

EXTEND NEW FLASHING 18" (457mm) MIN. UP SLOPE OR THAT ADDITIONAL AMOUNT TO PREVENT WATER BACKUP.

COVERBOARD INSULATION (IF REQUIRED)

THERMAL INSULATION (IF REQUIRED)

FIELD BASE MEMBRANE PLY(S) EXTEND UP SLOPE 6" (152mm)

UNDERLAYMENT OVERLAPS THE CAP MEMBRANE FLASHING PLY MIN. 6" (152mm)

PRIMARY ROOFING SYSTEM INSTALLED AS SPECIFIED

CAP MEMBRANE FLASHING PLY EXTEND MIN. 18" (457mm) UP SLOPE. NAIL AT TOP EDGE 8" (203mm) O.C.. ON HEAT WELDED FLASHING EMBED GRANULES IN FLASHING AREA (TYP.).

4" (102mm)


2" (51mm)

FIELD CAP MEMBRANE PLY EXTEND UP SLOPE 4" (102mm)

FIRST MEMBRANE FLASHING PLY EXTEND UP SLOPE MIN. 18" (457mm) AND ONTO FLAT OF ROOF 4" (102mm)

NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. SOPREMA ADHESIVES, CEMENTS, MASTICS, PRIMERS AND SEALANTS ARE REQUIRED WHERE INDICATED.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281	
		(330) 334-0066	
TITLE			
TRANSITION TO SLOPED ROOF			
SCALE	DWN	CHK	APPROVAL DATE
NONE	DMT	PR	9/1/05
DRAWING NUMBER			REV
AWBF-008			0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.