



FIELD CAP MEMBRANE PLY  
TURN-UP WALL 2" (51mm) MIN.  
(OPTIONAL)

MAXIMUM 24"  
HEIGHT (610mm)  
MINIMUM 8"  
(203mm)

2"  
(51mm)

PROJECT SPECIFIED WALL FINISH: METAL, MASONRY OR WOOD WALL PANEL SYSTEM, METAL COUNTER FLASHING OR COPING SYSTEM OR SOPREMA LIQUID MEMBRANE WATERPROOFING SYSTEM. SPECIFIED SYSTEM MUST WATERPROOF THE TOP FOUR INCHES OF THE FLASHING MEMBRANE PLY.

FASTENERS APPROX. 8" (203mm) O.C. OR BOTH PLIES FASTENED SIMULTANEOUSLY

POLYESTER CAP MEMBRANE FLASHING PLY HEAT WELDED

6"  
(152mm)

ON HEAT WELDED FLASHINGS EMBED GRANULES IN FLASHING AREA.

POLYESTER FIELD BASE AND CAP MEMBRANE PLIES ADHERED EITHER BY HEAT WELDING OR SOPREMA 2-PART ADHESIVE RIBBONS (REMOVE PLASTIC FILM IF PRESENT)

THERMAL INSULATION AND COVERBOARD APPLIED TO DECK AS SPECIFIED OR REQUIRED

PRIME MASONRY SUBSTRATE, ON WOOD FASTEN SOPREMA APPROVED BASE SHEET 8" (203mm) O.C. IN GRID PATTERN AND AT SIDE LAPS.

NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. SOPREMA ADHESIVES, CEMENTS, MASTICS, PRIMERS AND SEALANTS ARE REQUIRED WHERE INDICATED.



310 QUADRAL DRIVE  
WADSWORTH, OHIO 44281  
(330) 334-0066

TITLE WALL BASE FLASHING W/ OUT CANT			
SCALE NONE	DWN DMT	CHK PR	APPROVAL DATE 9/1/05
DRAWING NUMBER AWBF-012			REV 0

\*\* USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.