



MASONRY COPING STONE SET IN MORTAR BED (AS REQUIRED).

CUT-IN REGLET 1" MIN. DEEP, APPLY APPROVED CAULKING AS REQUIRED.

CONCRETE OR MASONRY WALL IN SOUND STRUCTURAL CONDITION.

PREPARE, LEVEL & PATCH SUBSTRATE W/ ACCEPTABLE PATCHING MORTAR PRIOR TO APPLICATION OF SOPREMA ALSAN LIQUID APPLIED PRIMER AND MEMBRANE (TYP.)

ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) EXTEND 4" MIN. HORIZONTALLY ONTO PREPARED AND PRIMED SUBSTRATE. (SEE NOTE #2).

FULLY ADHERED SBS MEMBRANE SYSTEM (AS SPECIFIED).

4" (10cm)

NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. A FULLY REINFORCED LIQUID MEMBRANE SYSTEM IS DEFINED AS AN ASSEMBLY CONSISTING OF TWO LIQUID RESIN APPLICATIONS & FABRIC REINFORCEMENT INSTALLED BETWEEN THE RESIN LAYERS. REFER TO DETAIL A-1 FOR ADDITIONAL INFORMATION.
3. APPLY TOP COAT OF ALSAN LIQUID RESIN OVER CURED MEMBRANE & BROADCAST TO REFUSAL WITH KILN-DRIED QUARTZ SILICA AT AREAS WHERE NEW MORTAR WILL CONTACT CURED LIQUID MEMBRANE.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066					
		TITLE SBS MEMBRANE W/LIQUID FLASHING W/MASONRY COPING STONE					
SCALE	NONE	DWN	PBF	CHK	KD	APPROVAL DATE	11/10/10
DRAWING NUMBER	B-14M					REV	0

\*\* USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.