



NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. A FULLY REINFORCED LIQUID MEMBRANE SYSTEM IS DEFINED AS AN ASSEMBLY CONSISTING OF TWO LIQUID RESIN APPLICATIONS & FABRIC REINFORCEMENT INSTALLED BETWEEN THE RESIN LAYERS. REFER TO DETAIL A-1 FOR ADDITIONAL INFORMATION.
3. APPLY TOP COAT OF ALSAN LIQUID RESIN OVER CURED MEMBRANE & BROADCAST TO REFUSAL WITH KILN-DRIED QUARTZ SILICA AT AREAS WHERE NEW MORTAR WILL CONTACT CURED LIQUID MEMBRANE.

| | | | | | | | |
|----------------|-------|---|-----|-----|----|---------------|----------|
| | | 310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066 | | | | | |
| | | TITLE SBS MEMBRANE MASONRY WALL LIQUID FLASHING W/MASONRY COPING CAP | | | | | |
| SCALE | NONE | DWN | PBF | CHK | KD | APPROVAL DATE | 11/10/10 |
| DRAWING NUMBER | B-4GM | | | | | REV | 0 |

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.