


NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. MINIMUM $\frac{1}{4}$ " TO MAXIMUM $\frac{1}{2}$ " SPACING BETWEEN LENGTHS OF TERMINATION BAR: ADD ADDITIONAL FASTENERS AS NEEDED TO ACHIEVE AND MAINTAIN COMPRESSION OF FLASHING MATERIALS.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066	
TITLE			
FOUNDATION WALL WITH DRAINAGE SYSTEM			
SCALE	DWN	CHK	APPROVAL DATE
NONE	TM	JP	12/29/09
DRAWING NUMBER			REV
BGW-1			0