


NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. CONCRETE DECK MUST BE PRIMED WITH ELASTOCOL 600-C OR OTHER APPROVED PRIMER PRIOR TO THE INSTALLTION OF COLPHENE 3000 MEMBRANE.
3. BOTH PLIES OF COLPHENE 3000 MEMBRANE SHALL EXTEND DOWN INTO THE DRAIN BOWL AND ENGAGE THE CLAMPING RING. REINFORCING MEMBRANE PLY SHALL BE IMBEDDED IN COLPHENE LIQUID MEMBRANE AND SHALL EXTEND OUT ONTO THE DECK A MINIMUM OF 12" ON ALL SIDES.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066	
TITLE DRAIN FLASHING (TYP.)			
SCALE	DWN	CHK	APPROVAL DATE
NONE	TM	JP	12/11/09
DRAWING NUMBER			REV
BGW-6			0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.