


NOTES:

1. USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, COLSTIX PDS AND APPROVED DETAILS WHILE CONSTRUCTING OTHER ROOF COMPONENTS TO EXCEED CURRENT EDITION REQUIREMENTS OF FM APPROVALS, SMACNA, NRCA, ANSI/SPRI ES 1-98 AND FLORIDA BUILDING CODE-RAS NO. 111 WITH THE MOST STRINGENT REQUIREMENTS OR RECOMMENDATIONS PREVAILING.
2. SOPREMA ADHESIVES, CEMENTS, MASTICS, PRIMERS AND SEALANTS ARE REQUIRED WHERE INDICATED.
3. ON SLOPES GREATER THAN 3/4:12, FIELD CAP MUST BE UNDER METAL EDGE AND STRIPPED-IN WITH ONE OF THE FOLLOWING METHODS: ALSAN FLASHING SYSTEM, HEAT WELDED OR HOT AIR WELDED USING A POLYESTER REINFORCED CAP PLY.
4. SEE DETAILS CXM-001, 002 & 003 FOR: WATERTIGHT SEAMS @ END LAPS; (T) JOINTS AND OTHER MEMBRANE CONNECTIONS; APPLYING SEAM SEALANT AT ALL FINISHED EDGES ON FIELD & FLASHING BASE PLIES.

| | | | |
|--|-----|-----------------------|---------------|
|  | | 310 QUADRAL DRIVE | |
| | | WADSWORTH, OHIO 44281 | |
| | | (330) 334-0066 | |
| TITLE | | | |
| COLSTIX™ METAL EDGE-GRAVEL STOP | | | |
| SCALE | DWN | CHK | APPROVAL DATE |
| NONE | DMT | PR | 6/15/03 |
| DRAWING NUMBER | | | REV |
| CXE-001 | | | 0 |

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.