


NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, COLSTIX PDS, APPROVED DETAILS AND ALSAN FLASHING (A.F.) APPLICATION AND COVERAGE DIRECTIONS.
2. A 20 MILS AF COATING HAS AN APPROXIMATE COVERAGE RATE OF 1.25 GALS/100 FT.² ALL COVERAGE RATES ARE APPROXIMATE, THEORETICAL AND DO NOT ACCOUNT FOR WASTE, SPILLAGE, IRREGULAR SURFACES AND APPLICATION TECHNIQUES THAT CAN ALSO VARY WITH INSTALLER. RATES MAY ALSO VARY DEPENDING UPON MATERIAL AND AMBIENT TEMPERATURE(S), SURFACE FINISH AND POROSITY OF THE SUBSTRATE.
3. ON SLOPES GREATER THAN 3/4:12, FIELD CAP MUST BE UNDER METAL EDGE AND STRIPPED IN WITH EITHER THE ALSAN FLASHING SYSTEM OR HEAT WELDED STRIP-IN FIELD CAP MEMBRANE PLY.

4. SEE DETAILS CXM-001, 002 & 003 FOR: WATERTIGHT SEAMS @ END LAPS; (T) JOINTS AND OTHER MEMBRANE CONNECTIONS; APPLYING SEAM SEALANT AT ALL FINISHED EDGES ON FIELD & FLASHING BASE PLIES.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281	
		(330) 334-0066	
TITLE COLSTIX™ METAL EDGE-STEEP SLOPE w/ AF			
SCALE NONE	DWN DMT	CHK PR	APPROVAL DATE 6/15/03
DRAWING NUMBER CXE-006			REV 0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.