


- POLYURETHANE CAULKING (BY OTHERS)
- COUNTERFLASHING AS REQUIRED (BY OTHERS)
- PREPARE, LEVEL & PATCH SUBSTRATE W/ ACCEPTABLE PATCHING MORTAR PRIOR TO APPLICATION OF SOPREMA ALSAN LIQUID APPLIED PRIMER AND MEMBRANE (TYP.)
- (1) PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) 2" (5cm) MIN. OVERLAP TO PROVIDE CONTINUOUS FLASHING.
- (1) PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) EXTEND THRU TO OUTSIDE OF OPENING & OVERLAP 2" (5cm) TO FORM SCUPPER FLASHING.
- (1) PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) EXTEND THRU TO OUTSIDE OF OPENING & OVERLAP 2" (5cm) TO FORM SCUPPER FLASHING.
- (1) PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE (SEE NOTE #2).
- PREPARED AND PRIMED SUBSTRATE (AS REQUIRED)

NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. A FULLY REINFORCED LIQUID MEMBRANE SYSTEM IS DEFINED AS AN ASSEMBLY CONSISTING OF TWO LIQUID RESIN APPLICATIONS & FABRIC REINFORCEMENT INSTALLED BETWEEN THE RESIN LAYERS. REFER TO DETAIL A-1 FOR ADDITIONAL INFORMATION.
3. METAL OR PVC SCUPPER SLEEVE THRU WALL OPTIONAL. SLEEVE WILL BE STRIPPED IN WITH ALSAN FULLY REINFORCED LIQUID APPLIED MEMBRANE SYSTEM.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066					
		TITLE THRU-WALL DRAIN FLASHING					
SCALE	NONE	DWN	PBF	CHK	BS	APPROVAL DATE	5/14/09
DRAWING NUMBER	D-2				REV	0	

\*\* USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.