



- CUT-IN REGLET 1" MIN. DEEP, APPLY APPROVED CAULKING AS REQUIRED.
- PREPARE, LEVEL & PATCH SUBSTRATE W/ ACCEPTABLE PATCHING MORTAR PRIOR TO APPLICATION OF SOPREMA ALSAN LIQUID APPLIED PRIMER AND MEMBRANE (TYP.)
- (1) PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) 2" (5cm) MIN. OVERLAP TO PROVIDE CONTINUOUS FLASHING (SEE NOTE #2).
- (1) PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) EXTEND THRU TO OUTSIDE OF OPENING & OVERLAP 2" (5cm) TO FORM SCUPPER FLASHING (SEE NOTE #2).
- (1) PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE (SEE NOTE #2).
- FULLY ADHERED SBS MEMBRANE SYSTEM (AS SPECIFIED).

2" (5cm) MIN.

2" MIN.

4" (10cm) MIN.

NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. A FULLY REINFORCED LIQUID MEMBRANE SYSTEM IS DEFINED AS AN ASSEMBLY CONSISTING OF TWO LIQUID RESIN APPLICATIONS & FABRIC REINFORCEMENT INSTALLED BETWEEN THE RESIN LAYERS. REFER TO DETAIL A-1 FOR ADDITIONAL INFORMATION.
3. METAL OR PVC SCUPPER SLEEVE THRU WALL OPTIONAL. SLEEVE WILL BE STRIPPED IN WITH ALSAN FULLY REINFORCED LIQUID APPLIED MEMBRANE SYSTEM.

| | | | | | | | |
|----------------|-------|--|-----|-----|----|---------------|----------|
| | | 310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066 | | | | | |
| | | TITLE THRU-WALL DRAIN LIQUID FLASHING OVER MOD BIT | | | | | |
| SCALE | NONE | DWN | PBF | CHK | KD | APPROVAL DATE | 11/11/10 |
| DRAWING NUMBER | D-2aM | | | | | REV | 0 |

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.