



CUT-IN REGLET 1" DEEP, APPLY APPROVED CAULKING, AS REQUIRED.

ONE OR TWO PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE WALL FLASHING BEYOND.

PREPARE, LEVEL & PATCH SUBSTRATE W/ ACCEPTABLE PATCHING MORTAR PRIOR TO APPLICATION OF SOPREMA ALSAN LIQUID APPLIED PRIMER AND MEMBRANE (TYP.)

Ⓐ ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) 4" (10cm) MIN. ONTO PREPARED AND PRIMED SUBSTRATE.

Ⓑ (1) PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) EXTEND MIN. OF 4" ONTO PREPARED & PRIMED DRAIN BOWL.

STRAINER AND CLAMP RING (OPTIONAL)

ASSURE FULL SATURATION OF FLEECE & CONTACT W/SUBSTRATE.

ALSAN FULLY REINFORCED LIQUID MEMBRANE (SEE NOTE #2).

2" MIN. 4" MIN.

ACCEPTABLE SCUPPER DRAIN ASSEMBLY PREPARE & PRIMER DRAIN BOWL AS REQ'D FOR ALSAN LIQUID MEMBRANE APPLICATION

NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. A FULLY REINFORCED LIQUID MEMBRANE SYSTEM IS DEFINED AS AN ASSEMBLY CONSISTING OF TWO LIQUID RESIN APPLICATIONS & FABRIC REINFORCEMENT INSTALLED BETWEEN THE RESIN LAYERS. REFER TO DETAIL A-1 FOR ADDITIONAL INFORMATION.
3. METAL OR PVC SCUPPER SLEEVE THRU WALL OPTIONAL. SLEEVE WILL BE STRIPPED IN WITH ALSAN FULLY REINFORCED LIQUID APPLIED MEMBRANE SYSTEM.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066						
		TITLE SCUPPER DRAIN FLASHING W/REGLET						
SCALE	NONE	DWN	PBF	CHK	BS	APPROVAL DATE	8/14/09	
DRAWING NUMBER	D-5a						REV	0

\*\* USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.