


NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. A FULLY REINFORCED LIQUID MEMBRANE SYSTEM IS DEFINED AS AN ASSEMBLY CONSISTING OF TWO LIQUID RESIN APPLICATIONS & FABRIC REINFORCEMENT INSTALLED BETWEEN THE RESIN LAYERS. REFER TO DETAIL A-1 FOR ADDITIONAL INFORMATION.
3. 4" WIDE ALSAN FULLY REINFORCED LIQUID MEMBRANE STRIP APPLIED OVER ALL RECOVERY BOARD JOINTS, ANGLE CHANGES AND VOIDS. FILL JOINTS & VOIDS W/ACCEPTABLE PATCHING MORTAR OR PASTE TO PRIOR TO APPLICATION OF LIQUID MEMBRANE STRIPS.

| | | | | | | | | |
|---|------|--|-----|-----|----|---------------|---------|---|
|  | | 310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066 | | | | | | |
| | | TITLE ROOF DRAIN FLASHING W/INSULATION | | | | | | |
| SCALE | NONE | DWN | PBF | CHK | BS | APPROVAL DATE | 8/14/09 | |
| DRAWING NUMBER | DI-1 | | | | | | REV | 0 |

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.