



- POLYURETHANE CAULKING (BY OTHERS)
- COUNTERFLASHING AS REQUIRED (BY OTHERS)
- PREPARE, LEVEL & PATCH SUBSTRATE W/ ACCEPTABLE PATCHING MORTAR PRIOR TO APPLICATION OF SOPREMA ALSAN LIQUID APPLIED PRIMER AND MEMBRANE (TYP.)
- (1) PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) 2" (5cm) MIN. OVERLAP TO PROVIDE CONTINUOUS FLASHING.
- (1) PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) EXTEND THRU TO OUTSIDE OF OPENING & OVERLAP 2" (5cm) TO FORM SCUPPER FLASHING.
- (1) PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) EXTEND THRU TO OUTSIDE OF OPENING & OVERLAP 2" (5cm) TO FORM SCUPPER FLASHING (SEE NOTE 2).
- FULLY ADHERED SBS MEMBRANE SYSTEM (AS SPECIFIED).
- APPROVED RECOVERY BOARD ATTACHED PER REQUIREMENTS.
- APPROVED RIGID INSULATION ATTACHED PER REQUIREMENTS.

- NOTES:
1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
 2. A FULLY REINFORCED LIQUID MEMBRANE SYSTEM IS DEFINED AS AN ASSEMBLY CONSISTING OF TWO LIQUID RESIN APPLICATIONS & FABRIC REINFORCEMENT INSTALLED BETWEEN THE RESIN LAYERS. REFER TO DETAIL A-1 FOR ADDITIONAL INFORMATION.
 3. 4" WIDE ALSAN FULLY REINFORCED LIQUID MEMBRANE STRIP APPLIED OVER ALL RECOVERY BOARD JOINTS, ANGLE CHANGES AND VOIDS. FILL JOINTS & VOIDS W/ACCEPTABLE PATCHING MORTAR OR PASTE TO PRIOR TO APPLICATION OF LIQUID MEMBRANE STRIPS.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066					
		TITLE THRU-WALL DRAIN FLASHING OVER MOD BIT W/INSULATION					
SCALE	NONE	DWN	PBF	CHK	KD	APPROVAL DATE	11/11/10
DRAWING NUMBER	DI-2M					REV	0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.