



METAL GRAVEL EDGE – ABRASE & CLEAN FLANGE W/ SPECIFIED CLEANER & SET IN BED OF ACCEPTABLE SEALER.

ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) EXTEND FULL WIDTH OF FLANGE & 4" (10cm) MIN. HORIZONTALLY ONTO PREPARED SURFACE.

FASTENERS 4" (10cm) O.C., STAGGERED 1".

ALSAN FULLY REINFORCED LIQUID MEMBRANE (SEE NOTE #2).

1/4" HEM

PREPARE, LEVEL & PATCH SUBSTRATE W/ACCEPTABLE PATCHING MORTAR PRIOR TO APPLICATION OF ALSAN LIQUID MEMBRANE SYSTEM (TYP).

CONTINUOUS CLEAT, FASTENED 6" (15cm) (MAX.)

GUTTER & SUPPORT STRAPS BY OTHERS. EXPOSED FASTENERS MUST BE FASTENED ALONG VERTICAL FACE OF DRIP EDGE & USE ACCEPTABLE SEALING WASHERS.

- NOTES:
1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
  2. A FULLY REINFORCED LIQUID MEMBRANE SYSTEM IS DEFINED AS AN ASSEMBLY CONSISTING OF TWO LIQUID RESIN APPLICATIONS & FABRIC REINFORCEMENT INSTALLED BETWEEN THE RESIN LAYERS. REFER TO DETAIL A-1 FOR ADDITIONAL INFORMATION.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066	
TITLE GUTTER EDGE FLASHING			
SCALE NONE	DWN PBF	CHK BS	APPROVAL DATE 5/07/09
DRAWING NUMBER E-3			REV 0

\*\* USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.