

EXTRUDED POLYSTYRENE INSULATION  
OR SOPREMA APPROVED PROTECTION  
PER SPECIFIER  
MINIMUM INSULATION LAYER REQUIRED

STONE BALLAST

SOPRAFILTER FABRIC

ELASTOPHENE SANDED OR  
ELASTOPHENE 180 SANDED


SOPRA-FLASH R

PRIMER

COLPHENE H (125 mils)

COLPHENE H (90 mils)

- NOTES:
1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS AND APPROVED DETAILS.
  2. ELASTOPHENE 180 SANDED IF USED DOES NOT REQUIRE AN ADDITIONAL PROTECTION COURSE CALL SOPREMA FOR DETAILS AND REQUIRED MINIMUM INSULATION LAYER

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281 (330) 334-0066	
TITLE COLPHENE H WITH STONE BALLAST			
SCALE	DWN	CHK	APPROVAL DATE
NONE	TM	JP	11/20/09
DRAWING NUMBER HRW-105			REV 0

\*\* USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.