



POLYURETHANE CAULKING (BY OTHERS)

COUNTERFLASHING AS REQUIRED (BY OTHERS)

PREPARE, LEVEL & PATCH SUBSTRATE W/ACCEPTABLE PATCHING MORTAR PRIOR TO APPLICATION OF ALSAN LIQUID MEMBRANE SYSTEM (TYP).

(1) PLY ALSAN FULLY REINFORCED LIQUID MEMBRANE (FLASHING GRADE) EXTEND TOP 4" (10cm) MIN. HORIZONTALLY ONTO PREPARED & PRIMED SUBSTRATE.

APPROVED CONTINUOUS CLOSED-CELL POLYETHYLENE ROD 1-1/2 X OPENING.

CONTINUOUS BOTTOM PLY OF ALSAN FULLY REINFORCED LIQUID MEMBRANE AT WALL-TO-DECK TRANSITION.

ALSAN FULLY REINFORCED LIQUID MEMBRANE (SEE NOTE #2).

APPROVED COMPRESSIBLE FILLER (AS REQUIRED).

8" (20cm) MIN.

2" (5cm) MIN.

2" (5cm) MIN.

2" (5cm) MIN.

NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. A FULLY REINFORCED LIQUID MEMBRANE SYSTEM IS DEFINED AS AN ASSEMBLY CONSISTING OF TWO LIQUID RESIN APPLICATIONS & FABRIC REINFORCEMENT INSTALLED BETWEEN THE RESIN LAYERS. REFER TO DETAIL A-1 FOR ADDITIONAL INFORMATION.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066					
		TITLE HORIZONTAL TO VERTICAL TRANSITION EJ FLASHING					
SCALE	NONE	DWN	PBF	CHK	BS	APPROVAL DATE	5/19/09
DRAWING NUMBER	J-1a					REV	0

\*\* USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.