


NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. SOPREMA FLASHING ADHESIVE, MASTIC, PRIMER (DEPENDING ON APPLICATION METHOD) REQUIRED WHERE INDICATED. SOPREMA SEALANT OR OWNER SPECIFIED SEALANT IS REQUIRED WHERE SEALANT IS INDICATED.
3. MINIMUM 6" (152mm) END LAP SEAMS AND "T" JOINTS ARE SEALED USING HOT AIR WELDED TECHNIQUES OR WHERE APPLICABLE HEAT WELDING OR 2-PART MEMBRANE ADHESIVE. FOLLOWING THE APPLICATION OF COLVENT TG, ALLOW 24 HOURS BEFORE APPLYING ADDITIONAL TORCHED OR HOT MOPPED PLIES.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281	
		(330) 334-0066	
TITLE COLVENT ROOF ASSEMBLY ON CONCRETE			
SCALE	DWN	CHK	APPROVAL DATE
NONE	DMT	PR	9/1/05
DRAWING NUMBER			REV
MISC-003			0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.