



- WARM PIPE—METAL SLEEVE REQ'D AT 150° F OR HIGHER.
- RAIN HOOD, CLAMP & CAULKING (BY OTHERS).
- SURFACE PREP MAX 1/8" BEYOND ALSAN FULLY REINFORCED LIQUID MEMBRANE.
- ALSAN FULLY REINFORCED LIQUID MEMBRANE SKIRT WRAPPED AROUND METAL SLEEVE W/ 2' (5cm) MIN. OVERLAP (SEE NOTE #2).
- NON-FLAMMABLE COMPRESSIBLE BATT INSULATION — FILL CAVITY BETWEEN PIPE AND METAL FLASHING SLEEVE.
- ALSAN FULLY REINFORCED LIQUID MEMBRANE COLLAR CUT INSIDE DIA. SAME SIZE AS BASE DIAMETER (SEE NOTE #2).
- SET BOTTOM FLANGE OF METAL SLEEVE INTO BED OF ACCEPTABLE SEALER.
- FULLY ADHERED SBS MEMBRANE SYSTEM (AS SPECIFIED).

NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. A FULLY REINFORCED LIQUID MEMBRANE SYSTEM IS DEFINED AS AN ASSEMBLY CONSISTING OF TWO LIQUID RESIN APPLICATIONS & FABRIC REINFORCEMENT INSTALLED BETWEEN THE RESIN LAYERS. REFER TO DETAIL A-1 FOR ADDITIONAL INFORMATION.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066					
		TITLE WARM PIPE PENETRATION FLASHING OVER MOD BIT					
SCALE	NONE	DWN	PBF	CHK	KD	APPROVAL DATE	11/11/10
DRAWING NUMBER	P-2M					REV	0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.