


NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS AND APPROVED DETAILS. FOR BUILDINGS; LESS THAN 40' IN HEIGHT IN GROUND ROUGHNESS CATEGORIES 'B' AND 'C' WITH MAX. 120 MPH WIND ZONE WITH FMA APPROVED 22 GA STEEL OR CONCRETE DECKS. FOR FASTENER SPACING ON OTHER DECK TYPES CONTACT SOPREMA CORPORATE TECHNICAL DEPARTMENT.
2. FMA PERIMETER DEFINITION: $X=4/10$ OF BUILDING HEIGHT OR $1/10$ THE BUILDING WIDTH, WHICHEVER IS THE LESSER DIMENSION. SOPREMA REQUIRES A MINIMUM OF 2 PERIMETER ROLLS. THE NUMBER OF PERIMETER ROLLS AND FASTENER DENSITIES MAY INCREASE WHEN WIND WARRANTY RIDERS ARE APPROVED.
3. PERIMETER FASTENER ROW SPACING: 60% OF FIELD FASTENER ROW WIDTH OR 20" (51cm).
CORNER FASTENER ROW SPACING: 40% OF FIELD FASTENER ROW WIDTH OR 13" (33cm).

(SEE DETAIL SFMA-036)

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066	
		TITLE SOPRAFIX-e FMA 1-150 W/ METAL BATTEN BAR	
SCALE	DWN	CHK	APPROVAL DATE
NONE	DMT	BS	8/13/07
DRAWING NUMBER			REV
SFMA-038			0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.