



PROJECT SPECIFIED WALL FINISH: METAL, MASONRY OR WOOD WALL PANEL SYSTEM, METAL COUNTER FLASHING OR COPING SYSTEM OR SOPREMA ALSAN FLASHING SYSTEM. SPECIFIED SYSTEM MUST WATERPROOF THE TOP FOUR INCHES OF THE FLASHING MEMBRANE PLY.

COLPHENE FR GR SELF-ADHERED TO DRY RESIDUE CLEAN CONCRETE SUBSTRATE PRIMED WITH SOPREMA APPROVED SA PRIMER

MAXIMUM 24"
(610mm)
HEIGHT
MINIMUM 8"
(203mm)

6" (152mm)
COLPHENE FR GR FIELD SEAM EITHER HEAT WELDED, HOT AIR WELDED OR SEALED USING SOPREMA TROWEL GRADE ADHESIVE OR 2-PART ADHESIVE

ON HEAT WELDED FLASHINGS EMBED GRANULES IN FLASHING AREA

POURED IN PLACE OR PRE-CAST CONCRETE WALL
PRIME THIS WALL AREA WITH ASPHALTIC PRIMER

FIELD CAP MEMBRANE PLY

SOPRAFIX BASE MEMBRANE PLY, FASTENED PER CURB, WALL AND PERIMETER LAYOUT DETAILS OR IN ACCORDANCE WITH AHJ

SOPRALENE STICK SELF-ADHERED 4" (102mm) ABOVE THE VERTICAL TERMINATION OF SOPRAFIX-e AND 4" OUT ONTO THE BASE PLY. PRIME FIELD FLASHING AREA WITH SOPREMA APPROVED SA PRIMER

COVERBOARD INSULATION (IF REQUIRED)
THERMAL INSULATION (IF REQUIRED)
ROOF DECK

SOPRAFIX-e IS TURNED UP WALL A MIN 4" (102mm) AND FULLY ADHERED TO ASPHALT PRIMED CLEAN DRY SUBSTRATE

NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. SOPREMA ADHESIVES, CEMENTS, MASTICS, PRIMERS AND SEALANTS ARE REQUIRED WHERE INDICATED.



310 QUADRAL DRIVE
WADSWORTH, OHIO 44281
(330) 334-0066

TITLE Soprafix Wall Base Flashing			
SCALE NONE	DWN DMT	CHK BS	APPROVAL DATE 9/28/06
DRAWING NUMBER SFWBF-006			REV 0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.