

ANNULAR RING SHANK NAIL
FASTENERS APPROX.
3" O.C. (76mm)
STAGGERED AND FLUSH.

METAL EDGE

PRIME FLANGE
BEFORE STRIPPING
SET FLANGE IN
SOPREMA MASTIC

CONTINUOUS
TAPERED
WOOD SHIM

WOOD NAILER
FASTENED AS
REQUIRED

MAXIMUM 24"
(610mm)
MINIMUM 8"
(203mm)

(152mm)
6" MIN.
TYP.

COVERBOARD INSULATION
(IF REQUIRED)

THERMAL INSULATION
(IF REQUIRED)

ROOF DECK

APPROVED SEALANT

HEAT WELDED CAP
MEMBRANE FLASHING PLY

HEAT WELDED POLYESTER
REINFORCING MEMBRANE PLY

PRIME MASONRY SUBSTRATE,
ON HEAT WELDED FLASHING
WITH WOOD SUBSTRATE,
FASTEN SOPREMA APPROVED
BASE SHEET 8" (203mm) O.C.
IN GRID PATTERN AND AT
SIDE LAPS.

(25.4mm)

8" 1"
(203mm)

ON HEAT WELDED FLASHINGS
EMBED GRANULES IN
FLASHING AREA.


FIELD CAP MEMBRANE PLY ON
HEAT WELDED FLASHINGS, EMBED
GRANULES IN FLASHING AREA.

FIRST MEMBRANE FLASHING
PLY EXTEND DOWN OUTSIDE
FACE TO BOTTOM OF WOOD
NAILER. SEAL SIDE LAPS.

SOPRAFIX BASE MEMBRANE PLY,
FASTENED PER CURB, WALL AND
PERIMETER LAYOUT DETAILS.

NOTES:

1. USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS AND APPROVED DETAILS WHILE CONSTRUCTING OTHER ROOF COMPONENTS TO EXCEED CURRENT EDITION REQUIREMENTS OF FM APPROVALS, SMACNA, NRCA, ANSI/SPRI ES-1 AND FLORIDA BUILDING CODE-RAS NO. 111 WITH THE MOST STRINGENT REQUIREMENTS OR RECOMMENDATIONS PREVAILING.
2. SOPREMA ADHESIVES, CEMENTS, MASTICS, PRIMERS AND SEALANTS ARE REQUIRED WHERE INDICATED.
3. WHEN A PROJECT SPECIFICATION REQUIRES SOPREMA TO WARRANT SHOP FORMED METAL(S), ROOFING CONTRACTOR MUST SUBMIT METAL SPECIFICATION AND ALL PROPOSED METAL DETAILS TO THE SOPREMA CORPORATE TECHNICAL DEPARTMENT FOR REVIEW/APPROVAL PRIOR TO BIDDING AND/OR INSTALLATION.
4. SEE SOPRAFIX MEMBRANE ATTACHMENT DETAIL SFMA-001.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281	
		(330) 334-0066	
TITLE SOPRAFIX WALL BASE FLASHING W/ METAL EDGE			
SCALE	DWN DMT	CHK BS	APPROVAL DATE 7/17/06
DRAWING NUMBER SFWBF-010			REV 0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.