



Technical Bulletin 1-09

Date: March 9, 2009

Subject: Revision of paragraph 2.28 B Roof Walkways
Revision of paragraph 3.24 B Roof Walkways

Effective on the above date, the existing paragraph below is being replaced by the new paragraph.

Existing paragraph 2.28 B:

Soprawalk, or an additional layer of membrane, may be heat welded, hot asphalt, or cold process applied. When heat welding, the granules on the cap sheet shall be embedded on the outside three (3") inches (76 mm) of the walkway. Walkways should be no longer than fifteen (15') feet (4.6 m) and shall have a four (4") inch (102 mm) gap between sections to permit drainage.

New paragraph 2.28 B:

Soprawalk, or an additional layer of membrane, may be heat welded, hot asphalt, or cold process applied. When heat welding, the granules on the cap sheet shall be embedded on the outside three (3") inches (76 mm) of the walkway. Walkways should be no longer than five (5') feet (1.5 m) and shall have a minimum four (4") inch (102 mm) gap between sections to permit drainage.

Existing paragraph 3.24 B:

Sections of walkway should be no longer than ten (10') feet (3 m) in length and gapped four (4") inches (102 mm) from adjoining sections.

New paragraph 3.24 B:

Sections of walkway should be no longer than five (5') feet (1.5 m) in length and gapped a minimum of four (4") inches (102 mm) from adjoining sections.

Bob Susinskas

Technical Manager, Soprema, Inc.