



FOUR TRI-FIXX PLATE AND FASTENERS - MAX. 8" (203mm) O.C. ON EACH DRAIN SIDE OF SOPRAFIX MEMBRANE. SEE NOTE 3.

FULLY BOND SOPRALENE REINFORCING MEMBRANE PLY ONTO SOPRAFIX MEMBRANE USING APPROVED METHODS. MIN. 5" (127mm) WIDE FINAL EDGE SEAL IS EITHER HEAT OR HOT AIR WELDED OR SEALED WITH 2-PART ADHESIVE (REMOVE PLASTIC BURN-OFF FILM IF PRESENT).

THERMAL INSULATION/LWIC SUMP-TO-DRAIN (TYPICAL)

ROOF DECK

FIELD BASE MEMBRANE PLY SET IN MIN. 6" (152mm) WIDE DIA. BED OF SOPREMA MASTIC-SEALING TO DRAIN FLANGE (REMOVE PLASTIC BURN-OFF FILM IF PRESENT).

CLAMPING RING

DRAIN BOWL

EXTEND FIELD MEMBRANE PLIES UNDER CLAMPING RING AND 1" (25mm) INTO BOWL WITH ROUNDED CUTS ONLY.

NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. SOPREMA ADHESIVES, CEMENTS, MASTICS, PRIMERS AND SEALANTS ARE REQUIRED WHERE INDICATED.
3. WHEN LWIC IS LESS THAN 2" (51mm) BUT MORE THAN 1-1/2" (38mm), USE MIN. 1.2" (30mm) TWIN LOC-NAIL 6" (152mm) O.C. OVERLAP FASTENER ROW WITH REINFORCING PLY MIN. 5" (127mm)

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066	
TITLE Tri-Fixx Assembly w/Membrane Drain Flashing			
SCALE NONE	DWN DMT	CHK PR	APPROVAL DATE 9/1/05
DRAWING NUMBER TFDR-002			REV 0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.