


NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS AND APPROVED DETAILS. FOR BUILDINGS; LESS THAN 60' IN HEIGHT IN GROUND ROUGHNESS CATEGORIES 'B' AND 'C' WITH MAX. 90 MPH WIND ZONE WITH SPECIFIC NEW FMA APPROVED LWC OR LWIC DECK SYSTEMS. SEE FM APPROVALS GUIDE FOR APPROVED DECK SYSTEMS.
2. FOR WIND RIDERS GREATER THAN 63 MPH: ROOFING CONTRACTOR IS RESPONSIBLE TO OBTAIN FROM SOPREMA'S CORPORATE TECHNICAL DEPARTMENT PRIOR TO BIDDING OR JOB-START, APPROVED FASTENING PATTERNS (FASTENER WITHDRAWAL VALUES CAN CHANGE ACTUAL FASTENER SPACING APPROVED) AND THE NUMBER OF REQUIRED PERIMETER ROLLS. IF APPROVAL IS NOT OBTAINED PRIOR TO INSTALLATION, THE COST OF INSTALLING ADDITIONAL FASTENERS WILL BE BORNE BY THE RESPONSIBLE PARTY.
3. PERIMETER DEFINITION: X=4/10 OF BUILDING HEIGHT OR 1/10 THE BUILDING WIDTH, WHICHEVER IS THE LESSER DIMENSION, WITH A MINIMUM OF 3 PERIMETER ROLLS ON PROJECTS WITH WIND EQUAL TO OR LESS THAN 63 MPH @ 3 SEC GUST. THE NUMBER OF PERIMETER ROLLS AND FASTENER DENSITIES WILL INCREASE WHEN SPECIAL WIND WARRANTY RIDERS ARE APPROVED.
4. PERIMETER FASTENER ROW SPACING: 60% OF FIELD FASTENER ROW WIDTH OR 20" (51cm). CORNER FASTENER ROW SPACING: 40% OF FIELD FASTENER ROW WIDTH OR 13" (33cm).

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281	
		(330) 334-0066	
TITLE			
TRI-FIXX FM 1-90 SYSTEM			
SCALE	DWN	CHK	APPROVAL DATE
NONE	DMT	PR	10/15/04
DRAWING NUMBER			REV
TFMA-006			0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.