

WOOD NAILERS AND CANT (IF REQUIRED) FASTENED AS SPECIFIED, (TYP)

MIN. 4" (102mm) CLEARANCE FROM PIPE TO TOP OF CURB; MIN. 2" (51mm) BETWEEN PIPES

TRI-FIXX PLATE AND FASTENERS 8" O.C. (203mm)

FASTENERS APPROX. 8" O.C. (203mm)

PRIME MASONRY SUBSTRATE, ON HEAT WELDED FLASHINGS, FASTEN SOPREMA APPROVED BASE SHEET 8" (203mm) O.C. IN GRID PATTERN AND AT SIDE LAPS.

ON HEAT WELDED FLASHINGS EMBED GRANULES IN FLASHING AREA

CAP MEMBRANE FLASHING PLY

FIRST MEMBRANE FLASHING PLY

FIELD CAP MEMBRANE PLY


SOPRAFIX FIELD BASE MEMBRANE PLY MECHANICALLY FASTENED IN-LAP WITH TRI-FIXX SYSTEM

THERMAL INSULATION /LWIC

ROOF DECK

NOTES:

1. USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS AND APPROVED DETAILS WHILE CONSTRUCTING OTHER ROOF COMPONENTS TO EXCEED CURRENT EDITION REQUIREMENTS OF FM APPROVALS, SMACNA, NRCA, ANSI/SPRI ES-1 AND FLORIDA BUILDING CODE-RAS NO. 111 WITH THE MOST STRINGENT REQUIREMENTS OR RECOMMENDATIONS PREVAILING.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281	
		(330) 334-0066	
TITLE Tri-Fixx Fastening at Piping Through Roof Deck			
SCALE	DWN	CHK	APPROVAL DATE
NONE	DMT	PR	10/15/04
DRAWING NUMBER TFPN-001			REV 0

\*\* USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.