

ANNULAR RING SHANK NAIL
FASTENERS APPROX.
3" O.C. (8cm)
STAGGERED AND FLUSH.

METAL EDGE

SET 4" FLANGE
IN SOPREMA MASTIC

EXTEND HIGH
TEMPERATURE
SELF-ADHERED
MEMBRANE DOWN
OUTSIDE FACE OF
SOLID MASONRY
WALL AND PAST
HORIZONTAL METAL
EDGE

CONTINUOUS
TAPERED
WOOD SHIM

WOOD NAILER

MINIMUM 2"
(5cm)

COVERBOARD INSULATION
(IF REQUIRED)

THERMAL INSULATION
(IF REQUIRED)

ROOF DECK

8" (20cm) OVERALL SIZE

6" (15cm)

2" (5cm)

ALSAN FLASHING BASE COAT WITH ALSAN PolyFleece REINFORCEMENT EMBEDDED INTO AND COVERED WITH BASE COAT WITHOUT WRINKLES OR FOLDS. TOTAL WET MIL THICKNESS-30 MILS AND APPROX. 22 DRY MILS (TYP).

ALSAN FLASHING FINISH COAT - 30 MILS; OPTIONAL TOP SURFACING OF EMBEDDED MATCHING GRANULES OR SOPREMA CURAL ALUMINIZER-24 MILS (16 DRY)

2" (5cm)

2" (5cm)

2" (5cm)

4" (10cm)

ALSAN FLASHING BASE COAT WITH ALSAN PolyFleece REINFORCEMENT EMBEDDED INTO AND COVERED WITH BASE COAT WITHOUT WRINKLES OR FOLDS. TOTAL WET MIL THICKNESS-30 MILS AND APPROX. 22 DRY MILS (TYP).

UNILAY MEMBRANE HEAT WELDED TO SOPRAPHIX PLATFORM MEMBRANE

SOPRAPHIX PLATFORM MEMBRANE, FASTENED PER CURB AND PERIMETER LAYOUT DETAILS.

NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPROVED DETAILS AND ALSAN FLASHING (A.F.) APPLICATION AND COVERAGE DIRECTIONS.
2. CURAL 24 WET MIL COVERAGE RATE (DRY 16 MILS) IS 1.5 GALS/100FT². ALSAN FLASHING 30 WET MILS COVERAGE RATE (22 DRY MILS) IS 1.87 GALS/100FT². ALL COVERAGE RATES ARE APPROXIMATE, THEORETICAL AND DO NOT ACCOUNT FOR WASTE, SPILLAGE, IRREGULAR SURFACES AND APPLICATION TECHNIQUES THAT CAN ALSO VARY WITH INSTALLER. RATES MAY ALSO VARY DEPENDING UPON MATERIAL AND AMBIENT TEMPERATURE(S), SURFACE FINISH AND POROSITY OF THE SUBSTRATE.



310 QUADRAL DRIVE
WADSWORTH, OHIO 44281
(330) 334-0066

TITLE				UNILAY HIGH WALL ALSAN FLASHING W/METAL EDGE	
SCALE	NONE	DWN DMT	CHK PR	APPROVAL DATE	10/15/04
DRAWING NUMBER	ULWBF-001				REV 0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.